

# POOL INSPECTION CHECKLIST

## POOL BARRIER / FENCE INSPECTION

- Is the pool fence at least 1.2 meters high all around?
- Are the gaps between vertical bars less than 100mm?
- Are all fence panels present and securely attached?
- Are fence posts firmly secured to the ground?
- Is the timber boundary fence structurally sound?
- Is the timber boundary fence firmly secured to the ground?
- Are gaps under the fence less than 100mm?
- Is any part of the fence damaged?
- Is there a child-resistant barrier (at least 1200mm high) protecting all living areas?

## POOL AREA SAFETY INSPECTION

- Are there any climbable objects within 1200mm outside the pool fence?
- Is the 300mm zone inside the fence clear of any climbable objects?
- Are there any objects within 900mm where the fence intersects another fence?
- Is a current CPR sign visible from inside the pool area?
- Do windows opening to the pool area have a maximum 100mm opening or security screen?
- Are there any potential handholds or footholds within 900mm of the fence top/bottom?
- For pool fences including patio/deck/pergola/balcony, is one side permanently open?

## POOL AREA SAFETY INSPECTION

- Are the gate hinges at least 900mm apart?
- Do the gates open outward, away from the pool area?
- Is the gate locking mechanism at least 1500mm from the ground?
- Do the gates self-close and self-lock from any open position?

## ADDITIONAL POOL SAFETY MEASURES

- Is a current CPR sign prominently displayed in the pool area?
- Has the pool been registered on the pool safety register?
- Has building approval been secured for the swimming pool/portable pool/spa?

## BOOK YOUR POOL SAFETY INSPECTION